



HALEY & ALDRICH, INC.
6500 Rockside Road
Suite 200
Cleveland, OH 44131
216.739.0555

October 6, 2025
File No. 0210977-003

Evergy Metro, Inc.
1200 Main Street
Kansas City, Missouri 64141

Attention: Jared Morrison – Director, Water and Waste Programs

Subject: Assessment Monitoring Program May 2025 Sampling Event
Statistically Significant Level Notification
La Cygne Generating Station
CCR System

Dear Mr. Morrison:


On behalf of Evergy Metro, Inc. (Evergy) and in accordance with Title 40 Code of Federal Regulations (40 CFR) § 257.95(g) of the U.S. Environmental Protection Agency Federal Coal Combustion Residuals (CCR) Rule (40 CFR §§ 257 and 261) effective October 19, 2015, and subsequent revisions, Haley & Aldrich, Inc. (Haley & Aldrich) has prepared this notification of detected statistically significant levels (SSL) for Appendix IV constituents. An Appendix IV constituent was detected above the groundwater protection standard (GWPS) established under 40 CFR § 257.95(h) the groundwater monitoring program for the CCR Landfill, Lower Air Quality Control (AQC) Impoundment, and Upper AQC Impoundment (collectively, CCR System) at the La Cygne Generating Station. Evergy provided Haley & Aldrich with groundwater monitoring data collected from the CCR System groundwater monitoring system that meets the requirements of 40 CFR § 257.91 and § 257.93. The results of the statistical analyses completed by Haley & Aldrich on September 19, 2025, of the May 2025 assessment monitoring sampling event data for each analyte/well combination indicate SSLs above GWPS for the following:

Constituent	Well ID
Lithium	MW-707B

If you have any questions or comments, please contact us.

Sincerely yours,
HALEY & ALDRICH, INC.

Steve Putrich, P.E.
Principal Consultant – Engineering Principal



Mark Nicholls, P.G.
Principal Consultant – Hydrogeologist

