

October 24, 2025

File No. 27224506.00

Evergy Metro, Inc.
818 South Kansas Avenue
Topeka, Kansas 66612

Attention: Jared Morrison –Director, Water and Waste Programs

**RE: Assessment Monitoring Program May 2025 Sampling Event
Notification of Statistically Significant Level (40 CFR § 257.95 (g))
CCR Landfill
Montrose Generating Station**

Dear Mr. Morrison:

On behalf of Evergy Metro, Inc. (Evergy), in accordance with Title 40 Code of Federal Regulations (40 CFR) 257.95(g) of the U.S. Environmental Protection Agency Federal Coal Combustion Residuals (CCR) Rule (40 CFR 257 and 261), effective October 19, 2015 and subsequent revisions, SCS Engineers has prepared this notification of statistically significant levels (SSLs) for an Appendix IV constituent above groundwater protection standards (GWPSs) established under 257.95 (h) for the CCR Landfill at the Montrose Generating Station. Evergy provided SCS Engineers with groundwater monitoring data collected from the unit groundwater monitoring system that meets the requirements of 40 CFR §257.91 and §257.93.

Consistent with statistical analyses completed from previous groundwater monitoring events, the results of the May 2025 assessment monitoring sampling event were validated by SCS Engineers on June 27, 2025. Statistical analyses completed by SCS Engineers on September 25, 2025, identified an SSL above the GWPS for the following constituent/well pair:

Constituent	Well ID
Cobalt	MW-605

Sincerely,



John R. Rockhold, R.G.
SCS Engineers



Daniel A. Wiens, P.E.
SCS Engineers

JR//JF/DW